

EPA ID#: 2050 System Name: Evergreen Colony

Sampler- Mr Tim Hofer Work Phone-(605)324-3303
Title- Business Manager
Address- 35691 156th Street
Faulkton SD 57438-6106

Location- City: Faulkton County: Faulk
Service Area- Homeowners Association
PWS Owner Type- Private Ownership
Water Supply Type- Groundwater Supply

Population Served- 106 Service Connections- 12

Sources for Evergreen Colony

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	TREAT SITE - #1				Emergency	Treatment Plant	Non-Vulnerable	Coagulation, Softening - Disinfection - Ultra Violet Filtration - Carbon Filter
05	#1		1580	4	Permanent	Groundwater	Non-Vulnerable	No Treatment

EPA ID#: 2050 System Name: Evergreen Colony

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	11/02/95	1952	3300	7.95	557	0	700	14.0	20.5	10.6	0.98	0.26	477.0	443	680	0	95	+0.28	0.1	2.67
01	Raw	06/26/02	2025	3380	7.92	558	0	722	14.2	20.5	9.6	0.11	0.02	484.0	428	681	0	91	+0.24	0.1	2.76
05	Raw	04/15/14	2026	3410	7.99	589	0	685	12.3	19.2	10.6	0.14	0.08	480.0	398	719	0	92	+0.31	0.0	2.71
Averages			2001	3363	7.95	568	0	702	13.5	20.1	10.3	0.41	0.12	480.3	423	693	0	93		0.1	2.71

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Treated	01/19/05	2003	3270	8.19	582	0	714	14.6	23.2	10.1	0.13	0.02	490.0	344	710	0	99	+0.59	0.1	2.69