

EPA ID#: 2150 System Name: Coca Cola Bottling Co

Sampler- Mr Byron Bultsma Work Phone-(605)716-8284
Title- Water Manager
Address- 2150 Coca Cola Lane
Rapid City SD 57702

Location- City: Rapid City County: Pennington
Service Area- Industrial/Agricultural
PWS Owner Type- Private Ownership
Water Supply Type- Groundwater Supply

Population Served- 75 Service Connections- 2

Months that System is Open to Public-Season Opening Date- January 1st Season Closing Date- December 31st

Sources for Coca Cola Bottling Co

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	TREAT SITE - #1				Permanent	Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites
03	#1	1991	1460	7	Permanent	Groundwater	Non-Vulnerable	Treatment At Plant

EPA ID#: 2150 System Name: Coca Cola Bottling Co

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Treated	12/08/94	174	325	7.69	164	0	3	2.0	42.0	19.0	0.05	0.03	3.0	13	200	0	183	+0.11	0.2	0.21
01	Treated	08/14/97	193	344	7.80	167	0	3	1.5	37.5	19.5	0.02	0.02	4.0	12	204	0	173	+0.13	0.3	0.20
03	Treated	07/29/03	186	338	7.81	168	0	3	1.7	39.8	19.8	0.03	0.02	3.0	10	205	0	181	+0.17	0.4	0.20
01	Treated	12/06/06	198	345	7.94	167	0	3	1.4	35.2	18.7	0.05	0.01	2.0	15	204	0	165	+0.21	0.5	0.22
Averages			188	338	7.81	167	0	3	1.7	38.6	19.3	0.04	0.02	3.0	13	203	0	176		0.4	0.21