

EPA ID#: 2153 System Name: Pineview Water Association

Sampler- Mr Bob Powles Work Phone-
Title- Water Manager
Address- 7963 Deerview Road
Piedmont SD 57769

Location- City: Rapid City County: Pennington
Service Area- Homeowners Association
PWS Owner Type- Private Ownership
Water Supply Type- Groundwater Supply

Population Served- 25 Service Connections- 10

Sources for Pineview Water Association

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	TREAT SITE - #1				Permanent	Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites
03	#1	1984	220	7	Permanent	Groundwater	Non-Vulnerable	Treatment At Plant

EPA ID#: 2153 System Name: Pineview Water Association

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	01/17/95	224	450	7.58	150	0	8	4.0	50.0	20.0	3.09	0.03	4.0	85	183	0	207	+0.03	0.2	0.28

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Treated	03/04/98	360	458	7.58	160	0	9	3.8	67.0	32.0	0.02	0.01	1.0	98	195	0	260	+0.05	0.0	0.36
03	Treated	04/29/03	286	476	7.81	156	0	10	4.0	51.0	19.8	0.78	0.05	3.8	85	190	0	209	+0.21	0.5	0.34
01	Treated	05/02/06	293	484	7.89	157	0	8	3.2	50.0	20.0	0.05	0.01	3.8	86	191	0	207	+0.28	0.5	0.32
01	Treated	06/23/09	300	488	7.89	158	0	10	3.3	47.2	20.4	0.05	0.01	3.8	72	193	0	202	+0.26	0.3	0.34
01	Treated	10/11/11	282	487	7.97	154	0	11	3.5	53.7	19.7	0.05	0.01	3.0	91	188	0	215	+0.39	0.5	0.34
01	Treated	09/18/14	288	490	7.92	155	0	11	3.6	59.4	19.7	0.11	0.00	4.8	96	189	0	230	+0.38	0.0	0.31
Averages			302	481	7.84	157	0	10	3.6	54.7	21.9	0.18	0.02	3.3	88	191	0	221		0.3	0.33