

EPA ID#: 2159 System Name: Stagebarn Sanitary District

Sampler- Mr Bob Powles Work Phone-
Title- Manager
Address- 7963 Deerview Road
Piedmont SD 57769

Location- City: Black Hawk County: Meade
Service Area- Homeowners Association
PWS Owner Type- Private Ownership
Water Supply Type- Purchased Groundwater Supply

Population Served- 293 Service Connections- 117

Sources for Stagebarn Sanitary District

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	TREAT SITE - #1					Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites
04	#2	1999	800			Groundwater	Non-Vulnerable	No Treatment
05	#1	1993	800	7		Groundwater	Non-Vulnerable	Treatment At Plant
07	BLACK HAWK WATER USERS DISTRICT	2007			Permanent	Purchased Groundwater	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only

EPA ID#: 2159 System Name: Stagebarn Sanitary District

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Treated	04/13/98	230	500	7.70	262	0	2	1.1	48.0	32.6	0.05	0.03	4.0	4	320	0	290	+0.37	0.3	0.15
01	Treated	04/29/03	243	484	7.80	257	0	3	0.9	41.6	32.4	0.05	0.05	4.3	10	314	0	14	+0.33	0.5	0.17
01	Treated	05/02/06	244	488	7.82	260	0	3	0.8	43.3	33.3	0.05	0.01	2.8	10	317	0	245	+0.37	0.5	0.16
Averages			239	491	7.77	260	0	3	0.9	44.3	32.8	0.05	0.03	3.7	8	317	0	183		0.4	0.16