

EPA ID#: 2172 System Name: Pleasant Valley Homeowners Association

Sampler- Mr Al Sage Work Phone-(605)391-7483
Title- Water Manager
Address- 5310 Ebony Place
Piedmont SD 57769

Location- City: Sturgis County: Meade
Service Area- Homeowners Association
PWS Owner Type- Private Ownership
Water Supply Type- Groundwater Supply

Population Served- 122 Service Connections- 23

Sources for Pleasant Valley Homeowners Association

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1	1976	1368	7	Permanent	Groundwater	Non-Vulnerable	No Treatment

EPA ID#: 2172 System Name: Pleasant Valley Homeowners Association

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langelier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langelier	NO3	F
01	Raw	12/06/96	218	410	7.60	194	0	2	1.0	65.0	13.0	0.05	0.03	1.0	23	237	0	216	+0.30	0.3	0.20
01	Raw	04/11/00	158	371	7.94	191	0	2	1.3	46.0	16.0	0.03	0.01	1.0	10	233	0	0	+0.36	0.2	0.20
01	Raw	02/11/03	221	396	7.71	199	0	2	1.0	46.1	17.4	0.05	0.05	1.0	10	243	0	187	+0.17	0.2	0.15
01	Raw	06/28/06	206	410	8.20	196	0	2	0.8	48.1	18.2	0.05	0.01	1.8	23	239	0	195	+0.67	0.2	0.15
01	Raw	11/18/08	257	446	7.81	200	0	95	0.5	1.0	0.5	0.05	0.01	1.0	23	243	0	5	-1.39	0.2	0.19
01	Raw	06/05/12	230	376	7.81	190	0	2	1.0	54.0	17.0	0.00	0.00	5.0	12	232	0	200	+0.42	0.4	0.40
01	Raw	08/26/14	200	360	7.88	190	0	3	1.0	45.8	17.6	0.05	0.04	0.0	0	232	0	187	+0.35	0.0	0.17
Averages			213	396	7.85	194	0	15	1.0	43.7	14.2	0.04	0.02	1.5	14	237	0	141		0.2	0.21