

EPA ID#: 2214 System Name: Spearfish Industrial Park

Sampler- Mr Mike Kyte Work Phone-(605)645-1276
Title- Contract Operator
Address- 1221 N Main
Spearfish SD 57783

Location- City: Spearfish County: Lawrence
Service Area-
PWS Owner Type- Private Ownership
Water Supply Type- Groundwater Supply

Population Served- 75 Service Connections- 30

Months that System is Open to Public-Season Opening Date- January 1st Season Closing Date- December 31st

Sources for Spearfish Industrial Park

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	SIP WELL	1977	304	5	Permanent	Groundwater	Non-Vulnerable	No Treatment

EPA ID#: 2214 System Name: Spearfish Industrial Park

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	04/08/02	247	488	7.71	259	0	3	1.4	58.3	18.7	0.64	0.05	5.5	10	316	0	223	+0.40	0.3	0.15
01	Raw	10/19/04	353	645	7.46	306	0	8	1.8	79.6	26.3	0.05	0.01	20.8	10	374	0	307	+0.34	1.0	0.14
01	Raw	10/20/10	286	508	7.73	265	0	3	1.6	73.5	19.1	0.03	0.03	4.0	10	323	0	262	+0.52	0.4	0.18
Averages			295	547	7.63	277	0	5	1.6	70.5	21.4	0.24	0.03	10.1	10	338	0	264		0.6	0.16