

# EPA ID#: 2277 System Name: Clark Rural Water-Kampeska

Sampler- Mr Terry Kaufman Work Phone-(605)532-5201  
Title- Manager  
Address- PO Box 162  
Clark SD 57225

Location- City: Clark County: Codington, Clark, Day, Hamlin  
Service Area- Other residential areas  
PWS Owner Type- Private Ownership  
Water Supply Type- Groundwater Supply

Population Served- 578 Service Connections- 236

## Sources for Clark Rural Water-Kampeska

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	KAMPESKA #1	2005	29	29	Permanent	Groundwater	Vulnerable	Treatment At Plant
02	KAMPESKA #2	2005	29	29	Permanent	Groundwater	Vulnerable	Treatment At Plant
03	TREATMENT PLANT				Permanent	Treatment Plant	Non-Vulnerable	Aeration Disinfection - Hypochlorites Filtration - Zeolite Fluoridation - H2SiF6

# EPA ID#: 2277 System Name: Clark Rural Water-Kampeska

## Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
03	Treated	12/18/09	364	714	7.42	214	0	11	3.5	74.2	27.5	0.03	0.02	84.0	10	261	0	298	+0.10	3.4	1.08