

EPA ID#: 2285 System Name: Sheridan Lake Highlands

Sampler- Mr Al Sage Work Phone-(605)391-7483
Title- Contract Operator
Address- 5310 Ebony Place
Piedmont SD 57769

Location- City: Rapid City County: Pennington
Service Area- Homeowners Association
PWS Owner Type- Private Ownership
Water Supply Type- Groundwater Supply

Population Served- 66 Service Connections- 22

Sources for Sheridan Lake Highlands

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1	2006	320	6	Permanent	Groundwater	Non-Vulnerable	Treatment At Plant
02	#2	2006	500	6	Emergency	Groundwater	Non-Vulnerable	No Treatment
03	#3	1994	125	6	Emergency	Groundwater	Non-Vulnerable	No Treatment
04	TREAT SITE - #1				Permanent	Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites Filtration - Green Sand Corrosion Control - Phosphates Sedimentation

EPA ID#: 2285 System Name: Sheridan Lake Highlands

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
04	Treated	05/14/08	172	235	7.06	84	0	11	0.6	22.2	6.0	0.45	0.01	11.0	10	103	0	80	-1.17	0.6	0.09
04	Treated	02/03/11	155	288	7.50	88	0	12	0.8	28.7	8.4	0.06	0.01	22.5	10	108	0	106	-0.60	2.8	0.08
04	Treated	01/29/14	115	237	6.54	71	0	14	0.7	27.2	6.6	0.08	0.00	12.2	0	87	0	95	-1.67	3.5	0.08
Averages			147	253	7.03	81	0	12	0.7	26.0	7.0	0.20	0.01	15.2	7	99	0	94		2.3	0.09