

EPA ID#: 2290 System Name: Creative Kids Too Preschool/Daycare

Sampler- Mr Al Sage Work Phone-(605)391-7483
Title- Operator
Address- 5310 Ebony Place
Piedmont SD 57769

Location- City: Rapid City County: Pennington
Service Area- Day Care Center
PWS Owner Type- Private Ownership
Water Supply Type- Groundwater Supply

Population Served- 87 Service Connections- 1

Months that System is Open to Public-Season Opening Date- January 1st Season Closing Date- December 31st

Sources for Creative Kids Too Preschool & Daycare

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	TREAT SITE - WELL #1				Permanent	Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites Filtration - Zeolite
03	WELL #1	1984	400	5	Permanent	Groundwater	Non-Vulnerable	Treatment At Plant

EPA ID#: 2290 System Name: Creative Kids Too Preschool/Daycare

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langelier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langelier	NO3	F
01	Raw	06/26/08	276	496	7.24	183	0	14	4.5	52.2	19.7	0.14	0.01	10.0	54	223	0	211	-0.29	0.8	1.13
01	Raw	03/29/11	300	479	7.80	182	0	15	4.7	53.2	19.3	0.09	0.01	5.7	53	222	0	212	+0.28	0.7	1.14
01	Raw	09/04/13	267	444	7.45	188	0	14	5.0	51.0	18.0	0.06	0.00	6.0	46	229	0	200	+0.03	0.7	1.20
Averages			281	473	7.50	184	0	14	4.7	52.1	19.0	0.09	0.01	7.2	51	225	0	208		0.7	1.16

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langelier	NO3	F
01	Treated	12/08/16	244	488	7.98	185	0	16	4.6	54.2	18.8	0.12	0.00	10.5	52	226	0	213	+0.48	0.8	1.23