

EPA ID#: 2307 System Name: Eagle Water Company

Sampler- Mr Rollin Sieveke Work Phone-
Title- Certified Operator
Address- PO Box 698
Lead SD 57754

Location- City: Lead County: Lawrence
Service Area- Homeowners Association
PWS Owner Type- Private Ownership
Water Supply Type- Surface Water Supply

Population Served- 25 Service Connections- 15

Sources for Eagle Water Company

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	RAW WATER FROM LDS				Permanent	Surface Water	Non-Vulnerable	Treatment At Plant
02	TREATMENT PLANT				Permanent	Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites Filtration -

EPA ID#: 2307 System Name: Eagle Water Company

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
02	Treated	06/19/12	274	487	8.15	274	0	2	0.4	62.4	28.4	0.03	0.04	4.0	10	334	0	273	+0.89	0.2	0.11